


Centra Linear Valve ASV-PAC-6

- D Montageanweisung
- DK Installationsvejledning
- ES Instrucciones de montaje
- F Instructions d'installation
- I Istruzioni di montaggio
- N Installationsinstruktioner
- NL Installatievoorschrift
- P Instruções de montagem
- S Installation instruktioner
- FI Asennusohje
- PL Instrukcja montażu

MOUNTING INSTRUCTIONS

0A.

PACKING FOR:
 PACKUNG FÜR:
 BOURRAGE DE PRESSE ETOUPE POUR:
 ANELLI PREMISTOPPA PER:
 PAKNING VOOR:
 PAKNING FOR:
 TIIVISTE VENTTIILILLE:
 PAKNING TILL:
 PRENSAESTOPAS PARA:



SAFETY:
 SICHERHEIT:
 SECURITÉ:
 SICUREZZA:
 VEILIGHEID:
 SÄKERHETFÖRESKRIFT:
 KÄYTTÖVARMUUS:
 SIKKERHET:
 SEGURIDAD:



VALVES FLANGED
 LINEAR
 -INST. INSTR.
 (MU1B1742GE23)

0B.

DFxD



DN80 - DN100

XFxB
 XFxD



DN100 - DN150

DFxB NI
 DFxC



DN100 - DN150

DFxB CI



DN100 - DN150

1.

ASSEMBLY SEQUENCE
REIHENFOLGE DES ZUSAMMENBAUS
SEQUENCE DE MONTAGE
SEQUENZA D'ASSEMBLAGGIO
MONTAGEVOLGORDE
MONTAGE-RÆKKEFOLGE
MONTASJEREKKEFØLGE
KOKOAMISJÄRJESTYS
HOPSÄTTNING
SECUENCIA DE MONTAJE

2.

Thoroughly remove the grinding paste.
Schleifpaste gründlich entfernen!
Retirer soigneusement la pâte abrasive.
Togliere completamente la pasta abrasiva.
Slijppasta grondig verwijderen.
Fjern slibepastaen grundigt.
Slípepastaen fjernes grundigt.
Poista hiomatahna perusteellisesti.
Ta bort slippastan omsorgsfullt.
Quitar la pasta de pulir esmeradamente.

3.

4.

5.

50 Nm

6.

Valve	Y1 when the valve is closed
Ventil	Y1 bei geschlossenem Ventil
Soupape	Y1 avec la soupape fermée
Valvola	Y1 a valvola chiusa
Ventiel	Y1 bij gesloten ventiel
Ventil	Y1 ved lukket ventil
Ventil	Y1 ved lukket ventil
Venttiili	Y1 suljetussa venttiilissä
Ventil	Y1 vid stängd ventil
Válvula	Y1 con la válvula cerrada
DFxB NI	
DFxC	89 mm
DFxD	
XFxB	
XFxD	107 mm
DFxB CI	89 mm



Manufactured for
and on behalf of
Pittway Sàrl, Z.A., La Pièce 4
1180 Rolle, Switzerland

For more information
homecomfort.resideo.com/europe
Ademco 1 GmbH, Hardhofweg 40,
74821 MOSBACH, GERMANY
Phone: +49 6261 810
Fax: +49 6261 81309